

NSF Product and Service Listings

These Listings were Last Updated on **Wednesday, June 09, 2004** at 4:15 AM Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Warning: NSF is concerned about fraudulent downloading and manipulation of website text. If you have received this listing in hard copy, always confirm this certification/listing information by going directly to <http://www.nsf.org/Certified/PwsComponents/Listings.asp?Company=28470&Standard=061&> for the latest most accurate information.

NSF/ANSI STANDARD 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings](#).

HENKEL LOCTITE CORPORATION

1001 TROUT BROOK CROSSING
ROCKY HILL, CT 06067
860-571-5100



Facility : # 1 USA

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Sealants Loctite [®] No More Leaks [™] Pipe Sealant	[1]	C. HOT	TS

[1] Certified for a maximum of 4.5 joints per liter.

Facility : SEABROOK, NH

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
-------------------	------	--------------------	------------------------

Adhesives

Hysol H4000	[1]	D. HOT	JSM
Loctite 7649 Adhesive Primer	4.5 joints/L	C. HOT	JNG
SpeedBonder Product H4000	[1]	D. HOT	JSM

[1] Certified for 28.5 sq. in. of a 1000 gallon tank.

Facility : CLEVELAND, OH

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Sealants			
Fixmaster Wet Surface Repair Putty 96583 1-lb Kit	[2]	C. HOT	SLT
Loctite® Resinol® 90C	[1]	C. HOT	SLT
Loctite® Resinol® RTC	[1]	C. HOT	SLT
Vibra Seal 503HV	>= 1/2"	C. HOT	SLT

[1] Maximum use level for residential applications is 31 sq. in./L (335 sq. in. per residence).

[2] Certified for a maximum surface area to volume ratio of 4 sq. in./L.
 Certified for use as a sealant for the following functions and sizes:
 Tanks - 50 gallons
 Pipes - 6" and greater
 Valves - 6" and greater
 Fittings - 6" and greater

Thread Compounds

Dri-Loc 204[3]	>= 1/2"	C. HOT	TC
Dri-Seal® 513	>= 1/2"	C. HOT	TS
Dri-Seal® 513 HV	>= 1/2"	C. HOT	TS

[3] Certified for a maximum of 21 joints per residence (2 joints per Liter).

Facility : SABANA GRANDE, PUERTO RICO

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Adhesives			

Loctite® 242 Threadlocker Adhesive	>= 1/2" C. HOT SLT
Loctite® 680 Retaining Compound[6]	>= 1/2" C. HOT ADH

[6] Maximum use: 10 (1/2") joints per liter.

Sealants

564 Thread Sealant	[2]	C. HOT TS
Loctite PST 561 Pipe Sealant Stick	[7]	C. HOT SLT
Loctite® 290 Threadlocker Adhesive	>= 1/2"	C. HOT SLT
Loctite® 565 PST® Pipe Sealant[5]	[2]	C. HOT TS
Sprinkler System Thread Sealant[5]	[2]	C. HOT TS
Sprinkler System Weld Sealant	>= 1/2"	C. HOT TS

[2] Maximum use: 50 (1/2") joints per residence (4.5 joints per liter).

[5] This product is Certified for use as a fitting and pipe sealant.

[7] Maximum of 5 joints per liter.

Thread Compounds

Hunting Interlock Seallube™ Tubular Thread Sealant - Field End	>= 1/2"	C. HOT TC
Hunting Interlock Seallube™ Tubular Thread Sealant - Mill End	>= 1/2"	C. HOT TC
Loctite® 248 Threadlocker Stick - Medium Strength	>= 1/2"	C. HOT TC
Loctite® 480 Instant Adhesive	[4]	C. HOT SLT
Loctite® 518 Flange Sealant[3]	>= 1/2"	C. HOT SLT
Loctite® Threadlocker Adhesive 243[3]	>= 1/2"	C. HOT TS
Seallube HTM-1001	>= 1/2"	C. HOT TC
Seallube LTF - 4444	>= 1/2"	C. HOT TC

[3] Maximum of 21 joints per residence (2 joints per liter).

[4] For residential use: No greater than (88) 1/2" joints per residence.

Facility : JILEMNICE, CZECH REPUBLIC

Joining and Sealing Materials

Trade Designation	Size	Water Contact Temp	Water Contact Material
Sealants			
Loctite 55 Pipe Sealing Cord[1]	>= 1/4" pipe	C. HOT	SLT
UNI-LOCK	>= 1/4" pipe	C. HOT	SLT
Tangit UNI-LOCK	>= 1/4" pipe	C. HOT	SLT

[1] Only products bearing the NSF Mark are Certified.

Thread Compounds

Loctite 55 Pipe Sealing Cord[1]	>= 1/4" pipe	C. HOT	TC
Tangit UNI-LOCK	>= 1/4" pipe	C. HOT	TC

[1] Only products bearing the NSF Mark are Certified.

Number of matching Manufacturers is 1

Number of matching Products is 32

Processing time was 0 seconds